Effect Date	North Kingstown Fire Department Standard Operating Guidelines	3000 Series Fire Operations
9 / 17	WORKING STRUCTURE FIRES CISTERN WATER SUPPLY	3021
Revision Date 11 / 17		Page 1 of 1

PURPOSE: The purpose of this policy is to create a standardized response plan for areas in North Kingstown where there is no positive pressure water supply available and water supply will be established through tanker trucks and portable water tanks.

Note: The following guideline is intended to be utilized in conjunction with/not in place of WORKING STRUCTURE FIRES - NON-HYDRANTED AREAS SOG #9021

When conducting firefighting operations in non-hydranted areas (without cisterns) water supply shall be supplied in the following manner:

1. Mutual aid tanker(s) to the scene.
2. Mutual aid engine company shall respond to designated fill site in vicinity of the incident.
3. Mutual aid tanker(s) in coordination with IC shall determine location and deployment of portable water tanks.
4. IC shall designate a dedicated engine company to establish water supply from the portable water tank to the emergency scene.
    a. Mutual Aid company OR NKFD engine company as determined by IC
5. IC should notify FAO when static water supply has been established and approximate flow rate (GPM's) to estimate water supply needs.
    a. FAO shall relay that information to the mutual aid water supply company.